



**Certificate of Conformity to IEC 61508  
 Safety Integrity Level (SIL) 1**

**Functional Safety of Safety-Related Programmable Electronic Systems**

The **QTRCO Inc, P551 Actuator Assembly (DA Series)** has been assessed and is considered capable for use in a low demand Safety Function **up to and including SIL 1**, with respect to random failure rates and architectural constraints.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **ESC Ltd Report: K011\_FM002 rev. 1.**

The product was assessed against the following failure mode:

- Ability to generate the minimum specified torque to move drive shaft to the predefined safe position when connected to valve.

The assessment was carried out to determine compliance with IEC 61508 with regards to:

- Random Hardware Failures;
- Architectural Constraints.

Device (No XRC PSTD)	$\lambda_{DU}$ (/hr)	$\lambda_{DD}$ (/hr)	$\lambda_S$ (/hr)	Device Type	SFF	PFD Achieved (refer to Note 1 & Note 2)
P551DA	1.1E-06	0.0E+00	0.0E+00	A	0%	4.9E-03
P551DA-TMLO	1.1E-06	0.0E+00	0.0E+00	A	0%	4.9E-03
Devices (With XRC PSTD)	$\lambda_{DU}$ (/hr)	$\lambda_{DD}$ (/hr)	$\lambda_S$ (/hr)	Device Type	SFF	PFD Achieved (refer to Note 1 & Note 2)
P551DA	9.3E-07	2.0E-07	0.0E+00	A	18%	4.2E-03
P551DA-TMLO	9.3E-07	2.0E-07	0.0E+00	A	18%	4.2E-03

**Note 1:** The analysis was based on the assumption that repairs would be carried out with a Mean Down Time (MDT) of 730 hours, a Proof Test Interval (PTI) of one year (8760 hours) and that the Partial Stroke Testing Device (PSTD) frequency (and associated response) is included in the assumed MDT period (i.e. not exceeding 730 hours).

**Note 2:** The remaining sensing, logic solver and additional final element sub-systems were excluded from the assessment, in order to allow for their PFD contributions, the devices were assessed against 20% of the SIL band.

The analysis covered use of additional features including the use of Top Mounted Lock-out and use of the XRCiser (XRC) PSTD.

**IMPORTANT:** It should be noted that this assessment does not include confirmation of the response time of the device. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Managing Director: Kenneth G L Simpson  
 Member of the IEC 61508 committee  
 Assessment Date: April 2020, valid to April 2022  
 Certificate: K011\_CT002 rev. 1

**ENGINEERING SAFETY CONSULTANTS LTD**  
 is ISO9001-certified by Global Group, itself a  
 UKAS-accredited ISO9001 certification  
 body  
 Reg: 12Q12086

**ENGINEERING SAFETY CONSULTANTS LTD**  
 Tuition House  
 27-37 St George's Road Wimbledon London SW19 4EU UK  
 Telephone/Fax: +44 (0)20 8542 2807  
 E-Mail: [info@esc.uk.net](mailto:info@esc.uk.net) Web: [www.esc.uk.net](http://www.esc.uk.net)  
 Registered in England and Wales: 7006868  
 Registered Office: 27-37 St George's Road Wimbledon London SW19 4EU