

## Certificate of Conformity to IEC 61508 Safety Integrity Level (SIL) 3 in Terms of Random Hardware Performance Requirements

### ***Functional Safety of Safety-Related Programmable Electronic Systems***

The **QTRCO Inc. F-Series quarter turn actuators for use as part of a valve assembly sub-system** has been assessed and is considered capable for use in a Low Demand Safety Function up to SIL 3 with regard to random failure rates.

The assessment was based on the assumptions, data provided, and recommendations given in:

- ESC Ltd report C119\_SV001 rev.4;
- Renewal Letter from QTRCO Inc., signed by Ed Holtgraver, CTO, dated 22<sup>nd</sup> January 2021.

The system was assessed against the following failure mode:

- Failure to generate required torque to operate connected valve.

The element assessed includes the following variants:

- Spring Return, Double Piston, up to 8 Springs;
- Double Acting.

The assessment was carried out to determine compliance with IEC 61508 with regards to:

- Random Hardware Failures (Predicted (Probability of Failure on Demand (PFD) was based on a 1-year proof test and a monthly Partial Stroke Test (PST));
- Architectural Constraints.

Model no.	Type	Config.	Achieved PFD	Achieved SIL (PFD)	Achieved SIL (Architecture)	Systematic Capability	Overall Achieved SIL
F-Series (with XRC PST)	Double Acting Actuator	1oo1	3.2E-03	1	1	3	1
		1oo2	2.2E-04	2	2	3	2
	Spring Return Actuator (up to 6 Springs)	1oo1	1.6E-03	2	2	3	2
		1oo2	1.0E-04	3	3	3	3
	Spring Return Actuator (8 Springs)	1oo1	2.0E-03	2	2	3	2
		1oo2	1.3E-04	3	3	3	3
F-Series (with PSTD)	Double Acting Actuator	1oo1	1.7E-03	2	2	3	2
		1oo2	1.1E-04	3	3	3	3
	Spring Return Actuator (up to 6 Springs)	1oo1	9.2E-04	2	2	3	2
		1oo2	6.1E-05	3	3	3	3
	Spring Return Actuator (8 Springs)	1oo1	1.2E-03	2	2	3	2
		1oo2	7.7E-05	3	3	3	3
F-Series		1oo1	4.2E-03	1	1	3	1

Model no.	Type	Config.	Achieved PFD	Achieved SIL (PFD)	Achieved SIL (Architecture)	Systematic Capability	Overall Achieved SIL
(without PSTD)	Double Acting Actuator	1oo2	3.0E-04	2	2	3	2
	Spring Return Actuator (up to 6 Springs)	1oo1	1.8E-03	2	2	3	2
		1oo2	1.2E-04	3	3	3	3
	Spring Return Actuator (8 Springs)	1oo1	2.3E-03	1	2	3	1
		1oo2	1.6E-04	3	3	3	3

Note 1: The sensing, logic solver and reaming final element sub-system have been excluded for the analysis and subsequently 80% of the SIL band has been allocated for their inclusion (e.g. SIL 2 band is modified to  $\geq 0.2E-03$  to  $< 0.2E-04$ ).

It must be noted that the above assessment is an example to demonstrate the PFD capability of the F-series actuator. A full assessment covering the proof test and repair strategy and PFD contribution of other sub-systems must be carried out to justify any PFD and SIL claim for the complete Safety Function.

IEC 61508 failure rates:

Model no.	Type	$\lambda$ (/hr)	$\lambda_{DU}$ (/hr)	$\lambda_{DD}$ (/hr)	$\lambda_S$ (/hr)	SFF (%)	Device Type
F-Series (with XRC PST)	Double Acting Actuator	9.7E-07	6.8E-07	2.9E-07	0.0E+00	30%	A
	Spring Return Actuator (up to 6 Springs)	1.2E-06	3.4E-07	7.1E-08	8.0E-07	72%	A
	Spring Return Actuator (8 Springs)	1.3E-06	4.4E-07	8.8E-08	8.0E-07	67%	A
F-Series (with PSTD)	Double Acting Actuator	9.7E-07	2.7E-07	7.0E-07	0.00+00	72%	A
	Spring Return Actuator (up to 6 Springs)	1.2E-06	1.7E-07	2.5E-07	8.0E-07	86%	A
	Spring Return Actuator (8 Springs)	1.3E-06	2.1E-07	3.1E-08	8.0E-07	84%	A
F-Series (without PSTD)	Double Acting Actuator	9.7E-07	9.7E-07	0.0E+00	0.0E+00	0%	A
	Spring Return Actuator (up to 6 Springs)	1.2E-07	4.1E-07	0.0E+00	8.0E-07	66%	A
	Spring Return Actuator (8 Springs)	1.3E-06	5.3E-07	0.0E+00	8.0E-07	60%	A

**XRC PST** – Automated partial stroke testing using QTRCO XRCISER.

**PSTD** - Automated partial stroke testing (with or without QTRCO XRCISER) that produces a valve signature (comparing air pressure/torque against valve movement).

**IMPORTANT:** It should be noted that this assessment does not include confirmation of the response time of the device. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.



Managing Director: Simon Burwood  
Member of the IEC 61511 Maintenance Committee (MT61511)  
Assessment Date: March 2014  
Renewal Date: February 2021, valid to February 2023  
Certificate: C119\_CT002 rev. 5

ENGINEERING SAFETY CONSULTANTS LTD  
is ISO9001-certified by Global Group, itself a  
UKAS-accredited ISO9001 certification  
body

Reg: 12Q12086

ENGINEERING SAFETY CONSULTANTS LTD  
Tuition House  
27-37 St George's Road Wimbledon London SW19 4EU UK  
Telephone/Fax: +44 (0)20 8542 2807  
E-Mail: info@esc.uk.net Web: www.esc.uk.net  
Registered in England and Wales: 7006868  
Registered Office: 27-37 St George's Road Wimbledon London SW19 4EU