



ENGINEERING SAFETY CONSULTANTS

The Global Provider of Functional Safety Expertise and Technical Consultancy

Certificate of Conformity to IEC 61508 / IEC 61511 Safety Integrity Level (SIL) 1/2

Functional Safety of Safety-Related Programmable Electronic Systems

Manufacturer: Tyco Fire & Security GmbH (TFSG)
Victor Von Bruns-Strasse 21
8212 Neuhausen am Rheinfall
Schaffhausen
Switzerland

The **TFSG, SNM800 Sounder Notification Module** (function of this module is to activate and monitor externally powered sounders) has been assessed and is considered capable for use in a low demand Safety Function up to SIL 1 or SIL 2 with regard to systematic capability (assessed under the Prior Use route), random failure rate and architectural constraint.

- SIL 1 SIF suitable with simplex configuration;
- SIL 2 SIF suitable with duplex configuration.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Engineering Safety Consultants Ltd Report: D152_SV004 rev.3, which includes details associated with the Safety Manual requirements in Appendix C;**
- **Engineering Safety Consultants Ltd Report: D152_PU001 rev.3;**
- **Renewal Letter from Tyco Fire & Security GmbH, signed by Deepika Sahni, Principal Regulatory Engineer, Dated 8th April 2021.**

The assessment was carried out against failure modes where the detector was unable to detect an alarm condition and process alarms over the addressable system.

The assessment was carried out to determine compliance with IEC 61508 (2010 Edition) with regards to:

- Random Hardware Failure with Predicted PFD <3.0E-03 (assuming a 1 year proof test interval and average repair time of 168 hrs);
- Architectural Constraint (Type B, SFF >60%, <90%);
- Systematic Capability against IEC 61511 (2016 Edition) Prior Use.

IMPORTANT: It should be noted that this assessment does not include confirmation of the response time of the devices. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Managing Director: Simon Burwood
Member of IEC 61508 (MT61808-1-2) & IEC 61511 (MT61511) Maintenance Committees
Assessment Date: April 2015
Renewal Date: April 2021, valid to April 2023
Certificate: D152_CT004 rev. 6

ENGINEERING SAFETY CONSULTANTS LTD
is ISO9001-certified by Global Group, itself a
UKAS-accredited ISO9001 certification
body

Reg: 12Q12086

ENGINEERING SAFETY CONSULTANTS LTD
2nd Floor, Exchequer Court, 33 St. Mary Axe,
London, EC3A 8AA UK
Telephone/Fax: +44 (0)20 8542 2807
E-Mail: info@esc.uk.net Web: www.esc.uk.net
Registered in England and Wales: 7006868
Registered Office: 33 St. Mary Axe, London, EC3A 8AA