



## ENGINEERING SAFETY CONSULTANTS

*The Global Provider of Functional Safety Expertise and Technical Consultancy*

---

# Certificate of Conformity to IEC 61508 / IEC 61511 Safety Integrity Level (SIL) 2

---

### ***Functional Safety of Safety-Related Programmable Electronic Systems***

**Manufacturer:** Tyco Fire & Security GmbH (TFSG)  
Victor Von Bruns-Strasse 21  
8212 Neuhausen am Rheinfall  
Schaffhausen  
Switzerland

The **T2000, MX & ZX Fire Panel** has been assessed and is considered capable for use in a low demand Safety Function up to SIL 2 with regard to systematic capability (assessed under the Prior Use route), random failure rate and architectural constraint. This assessment is valid utilizing either **CPU800** or **CPU801**.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Technis Report No. T432, Issue 4.0;**
- **Engineering Safety Consultants Ltd Report: D152\_SV008 rev.4, which includes details associated with the Safety Manual requirements in Appendix C;**
- **Engineering Safety Consultants Ltd Report: D152\_PU001 rev.3;**
- **Renewal Letter from Tyco Fire & Security GmbH, signed by Deepika Sahni, Principal Regulatory Engineer, Dated 8<sup>th</sup> April 2021.**

The product was assessed against the following failure modes:

- Failure to respond (executive output);
- Failure to respond (audible output).

The assessment was carried out to determine compliance with IEC 61508 (2010 Edition) with regards to:

- Random Hardware Failure with Predicted PFD <2.0E-03 (assuming a 1 year proof test interval and average repair time of 168 hrs);
- Architectural Constraint (Type B, SFF >90%, <99%);
- Systematic Capability against IEC 61511 (2016 Edition) Prior Use.

**IMPORTANT:** It should be noted that this assessment does not include confirmation of the response time of the devices. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Managing Director: Simon Burwood  
Member of IEC 61508 (MT61808-1-2) & IEC 61511 (MT61511) Maintenance Committees  
Assessment Date: April 2015  
Renewal Date: April 2021, valid to April 2023  
Certificate: D152\_CT008 rev. 7

ENGINEERING SAFETY CONSULTANTS LTD  
is ISO9001-certified by Global Group, itself a  
UKAS-accredited ISO9001 certification  
body

Reg: 12Q12086

**ENGINEERING SAFETY CONSULTANTS LTD**  
2nd Floor, Exchequer Court, 33 St. Mary Axe,  
London, EC3A 8AA UK  
Telephone/Fax: +44 (0)20 8542 2807  
E-Mail: [info@esc.uk.net](mailto:info@esc.uk.net) Web: [www.esc.uk.net](http://www.esc.uk.net)  
Registered in England and Wales: 7006868  
Registered Office: 33 St. Mary Axe, London, EC3A 8AA