



---

## Certificate of Conformity to IEC 61508 Safety Integrity Level (SIL) 2

---

### **Functional Safety of Safety-Related Programmable Electronic Systems**

The **SEFI, LEONIS / DC520 Fire Control Panel (FCP)** has been assessed and is considered capable for use in a low demand Safety Function with a SIL requirement of up to (including) SIL 2.

The assessment was carried out to determine compliance with IEC 61508 route 1<sub>H</sub> (2010 Edition) with regards to:

- Random Hardware Failure (Predicted PFD) with a Mean Down Time (MDT) of 168 hours, a Proof Test Interval (PTI) of 1 year (8760 hours), a Proof Test Coverage (PTC) of 100% or 95% and an Overhaul Interval of 15 years (131400 hours);
- Architectural Constraint (Type B, Predicted SFF = 95.9%);
- Systematic Capability of SC 2.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Engineering Safety Consultants (ESC) Ltd Report: H187\_FM001 rev. 3;**
- **ESC Ltd Report: H187\_SM001 rev. 2;**
- **ESC Ltd Report: H187\_SM002 rev. 2;**
- **ESC Ltd Report: H187\_SM003 rev. 2.**

The product was assessed against the following failure mode:

- **Failure to transmit output signal (via relay output) on acquisition of input signal (alarm – fire detection or detection device offline).**

The system assessed comprises the following modules/sub-elements:

- M10R;
- MPE;
- ELOT;
- BPS;
- ELFP.

The assessment results are as follows:

Device	PFD Target (20% of SIL 2 band)	Proof Test Coverage (PTC)	Predicted PFD	Predicted SFF	HFT	Type	Predicted Overall SIL
LEONIS / DC520 Fire Control Panel	2.00E-03	100%	6.1E-04	95.9%	0	B	2
		95%	9.1E-04	95.9%	0	B	2

**IMPORTANT:** It should be noted that this assessment does not include confirmation of the response time of the device. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Managing Director: Simon Burwood  
Member of IEC 61508 (MT61808-1-2) & IEC 61511 (MT61511) Maintenance Committees  
Assessment Date: August 2020, valid to August 2022  
Certificate: H187\_CT001 rev. 4

**ENGINEERING SAFETY CONSULTANTS LTD**  
is ISO9001-certified by Global Group, itself a  
UKAS-accredited ISO9001 certification  
body

Reg: 12Q12086

**ENGINEERING SAFETY CONSULTANTS LTD**  
2nd Floor, Exchequer Court, 33 St. Mary Axe,  
London, EC3A 8AA UK  
Telephone/Fax: +44 (0)20 8542 2807  
E-Mail: [info@esc.uk.net](mailto:info@esc.uk.net) Web: [www.esc.uk.net](http://www.esc.uk.net)  
Registered in England and Wales: 7006868  
Registered Office: 33 St. Mary Axe, London, EC3A 8AA