



ENGINEERING SAFETY CONSULTANTS

The Global Provider of Functional Safety Expertise and Technical Consultancy

Certificate of Conformity to IEC 61508 Safety Integrity Level (SIL) 2

Functional Safety of Safety-Related Programmable Electronic Systems

Manufacturer: Tyco Fire & Security GmbH (TFSG)
Victor Von Bruns-Strasse 21
8212 Neuhausen am Rheinfall
Schaffhausen
Switzerland

The **TFSG, Generation 6 P detectors** have been assessed and are considered capable for use in a low demand Safety Function up to SIL 2, with regards to random hardware failures and architectural constraints.

It should be noted that Systematic Capability (SC) has not been addressed as part of this certificate.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Generation 6 P Review Report Iss3, by TFSG dated 02/07/2012;**
- **Generation 6 P FMEDA Iss2, by TFSG dated 06/06/2012;**
- **Renewal Letter from Tyco Fire & Security GmbH, signed by P.W. Cottrell, R&D Engineer – Sensor Team, Dated 8th April 2021;**
- **Addition of 835P / 855P products to B118_CT002 Certificate Letter from Tyco Fire & Security GmbH, signed Deepika Sahni, Principal Regulatory Engineer, Dated 2nd February 2022.**

The assessment was carried out against failure modes where the detectors were unable to detect and process alarms over the addressable system. The following models were assessed:

- **Generation 6 850P;**
- **Generation 6 856P;**
- **Generation 6 840P;**
- **Generation 6 830P;**
- **Generation 6 835P;**
- **Generation 6 855P;**
- **Generation 6 FC460P;**
- **Generation 6 4098-6252 Optical;**
- **Generation 6 4098-6232 Optical.**

The assessment was carried out to determine compliance with IEC 61508 (2010 Edition) with regards to:

- Random Hardware Failures (Predicted PFD <2.0E-03), based on a one-year proof test interval;
- Architectural Constraint (Type B, SFF >90%, <99%).

IMPORTANT: It should be noted that this assessment does not include confirmation of the response time of the devices. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Page 1 of 2

ENGINEERING SAFETY CONSULTANTS LTD
is ISO9001-certified by Global Group, itself a
UKAS-accredited ISO9001 certification
body

Reg: 12Q12086

ENGINEERING SAFETY CONSULTANTS LTD
2nd Floor, Exchequer Court, 33 St. Mary Axe,
London, EC3A 8AA UK
Telephone/Fax: +44 (0)20 8542 2807
E-Mail: info@esc.uk.net Web: www.esc.uk.net
Registered in England and Wales: 7006868
Registered Office: 33 St. Mary Axe, London, EC3A 8AA



ENGINEERING SAFETY CONSULTANTS

The Global Provider of Functional Safety Expertise and Technical Consultancy

The following models are covered by this certificate:

Model Name	Product Description	λ DU Dangerous Undetected Failures	λ DD Dangerous Detected Failures	λ S Safe Failures	Safe Failure Fraction	PFD _{avg}
850P / 855P	Optical Smoke Detector with s/c Isolator	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	92%	1.3E-03
856P	Optical Smoke Detector with s/c Isolator	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	92%	1.3E-03
840P	Optical Smoke Detector	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	92%	1.3E-03
830P / 835P	Optical Smoke Detector	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	92%	1.3E-03
FC460P	Optical Smoke Detector	2.5E-07 /hr	3.0E-06 /hr	4.5E-07 /hr	92%	1.2E-03
4098-6252 Optical	Optical Smoke Detector with s/c Isolator	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	93%	1.3E-03
4098-6232 Optical	Optical Smoke Detector	2.6E-07 /hr	3.2E-06 /hr	4.5E-07 /hr	92%	1.3E-03

It should be noted that all variant models stated above are functionally equivalent to the 850P / 855P, 830P / 835P or FC460P detectors.

Managing Director: Simon Burwood

Member of IEC 61508 (MT61808-1-2) & IEC 61511 (MT61511) Maintenance Committees

Assessment Date: February 2012

Renewal Date: April 2021, valid to April 2023

Certificate: B118_CT002 rev. 7

Page 2 of 2

ENGINEERING SAFETY CONSULTANTS LTD
is ISO9001-certified by Global Group, itself a
UKAS-accredited ISO9001 certification
body

Reg: 12Q12086

ENGINEERING SAFETY CONSULTANTS LTD

2nd Floor, Exchequer Court, 33 St. Mary Axe,
London, EC3A 8AA UK

Telephone/Fax: +44 (0)20 8542 2807

E-Mail: info@esc.uk.net Web: www.esc.uk.net

Registered in England and Wales: 7006868

Registered Office: 33 St. Mary Axe, London, EC3A 8AA