



ENGINEERING SAFETY CONSULTANTS

The Global Provider of Functional Safety Expertise and Technical Consultancy

IEC 61508 Safety Integrity Level Capability Certificate

Functional Safety of Safety-Related Programmable Electronic Systems

Manufacturer: Tyco Fire & Security GmbH (TFSG)
Victor Von Bruns-Strasse 21
8212 Neuhausen am Rheinfall
Schaffhausen
Switzerland

The **TFSG, SNM800 Sounder Notification Module** (function of this module is to activate and monitor externally powered sounders) has been assessed and is considered capable for use in a low demand Safety Function up to (and including) SIL 1 / SIL 2 with regard to systematic capability (assessed under the Prior Use route), random hardware failures and architectural constraints.

The assessment was based on the assumptions, data provided, and recommendations given in:

- **Engineering Safety Consultants Ltd Report: D152_SV004 rev.4, which includes details associated with the Safety Manual requirements in Appendix B;**
- **Engineering Safety Consultants Ltd Report: D152_PU001 rev.4;**
- **Renewal Letter from Tyco Fire & Security GmbH, signed by Deepika Sahni, Principal Regulatory Engineer, Dated 27th April 2023.**

The assessment was carried out against failure modes where the detector was unable to detect an alarm condition and process alarms over the addressable system.

The assessment was carried out to determine compliance with IEC 61508 (2010 Edition) with regards to:

- SIL 1 with a HFT = 0 via Route 1_H (Simplex Configuration);
- SIL 2 with a HFT = 1 via Route 1_H (Redundant Configuration);
- Architectural Constraint (Type B, SFF >60% - <90%);
- Systematic Capability against IEC 61508 (2010 Edition) via Route 2_s.

Device	λ_{DU} (/hr)	λ_{DD} (/hr)	λ_S (/hr)	SFF (%)	Device Type	Estimated SIL Capability
SNM800 Sounder Notification Module	3.1E-07	3.3E-07	1.4E-07	60	B	SIL 1 (1oo1) SIL 2 (1oo2)

Note 1: The SIL of a complete SIF (sensor, logic solver and final element subsystems) must be verified to calculate the required PFD / PFH, considering any redundancy, Proof Test Interval (PTI), Proof Test Coverage (PTC), Mission Time and Mean Time To Restoration (MTTR) for all elements included in the SIF. Each subsystem should be verified to ensure compliance with the minimum HFT requirements.

IMPORTANT: It should be noted that this assessment does not include confirmation of the response time of the device. For response times (along with any relevant assumptions) reference should be made to the Safety Manual of each device and the total SIF response time **MUST** be compared against the process safety time for the specific application.

Managing Director: Simon Burwood
Assessment Date: April 2015
Renewal Date: April 2023, valid to April 2025
Certificate: D152_CT004 rev. 7

ENGINEERING SAFETY CONSULTANTS LTD
2nd Floor, Exchequer Court, 33 St. Mary Axe,
London, EC3A 8AA UK
Telephone/Fax: +44 (0)20 8542 2807
E-Mail: info@esc.uk.net Web: www.esc.uk.net
Registered in England and Wales: 7006868
Registered Office: 33 St. Mary Axe, London EC3A 8AA