Document number:	A114_CT001 rev. 5
Dated:	24-Jan-25
Expiry date:	24-Jan-27

IEC 61508 Functional Safety Capability Statement

Tyco Fire & Security GmbH (TFSG), T2000 MX & ZX Fire Panel

Manufacturer:	Tyco Fire & Security GmbH (TFSG) Victor Von Bruns-Strasse 21, 8212 Neuhausen am Rheinfall, Schaffhausen, Switzerland
Product:	Fire Panel
Model:	T2000 MX & ZX

Application:	Low Demand Mode Safety Instrumented Function
Safety Function:	Upon detection of a failure to provide an executive output signal or audible alarm output in respond to a valid input from a fire detector, action is initiated via the Fire Panel (Sensing, logic solver and final element subsystems not part of this analysis)
Applied standard:	IEC 61508 Ed2 2010 Parts 1-3 & IEC 61511 Ed1
Systematic Capability:	Suitable up to SIL 2
Applicable report:	Technis Report No. T432, Issue 4.0 Environmental Resources Management Ltd Report: A114_TR001 rev. 5

Assessment Route:	1_H
Hardware Fault Tolerance:	0
Type:	B
Application restrictions:	None

It should be noted that for a device to meet a required SIL that the SIL AC and SIL SC of the device needs to both be met. In addition to this, the required Probability of Failure on Demand (PFD) value for the complete Safety Instrumented Function (SIF) needs to adhere to the SIL PFD ranges.

IMPORTANT: It should be noted that this assessment considers only the Tyco Fire & Security GmbH (TFSG), T2000 MX & ZX Fire Panel. It does not cover opening and closing time requirements and a random hardware failures assessment must be conducted for the entire safety function for each application as per the appropriate Safety Requirements Specification.

The Tyco Fire & Security GmbH (TFSG), T2000 MX & ZX Fire Panel has been assessed and is considered capable for use in a low demand mode safety function up to (and including) SIL 2 with regards to random hardware failures, architectural constraints and Systematic Capability.

Note 1: The SIL of a complete SIF (sensor, logic solver and final element subsystems) must be verified to calculate the required PFD / Probability of Failure per Hour (PFH), considering any redundancy, Proof Test Interval (PTI), Proof Test Coverage (PTC), Mission Time and Mean Time To Restoration (MTTR) for all elements included in the SIF. Each subsystem should be verified to ensure compliance with the minimum HFT requirements.

© Copyright 2025 by The ERM International Group Limited and/or its affiliates ('ERM'). All Rights Reserved.

Document number:	A114_CT001 rev. 5
Dated:	24-Jan-25
Expiry date:	24-Jan-27

Chantal Sealey FS Eng (TÜV Rheinland) Assessor chantal.sealey@erm.com	Simon Burwood FS Expert (TÜV Rheinland) Assessment Authority simon.burwood@erm.com

© Copyright 2025 by The ERM International Group Limited and/or its affiliates ('ERM'). All Rights Reserved.