Document number:	E058_CT001 rev. 6
Dated:	22-Jan-26
Expiry date:	22-Jan-29

IEC 61508 Functional Safety Capability Statement

ROSS Pneumatrol Ltd, VTP Poppet Valve with SXH / SXD Actuator Assembly

Manufacturer:	ROSS Pneumatrol Ltd Blackburn Rd, Oswaldtwistle, Accrington BB5 4WZ
Product:	Poppet Valve with Actuator Assembly
Model:	VTP Poppet Valve with SXH / SXD Actuator Assembly

Application:	Low Demand Mode Safety Instrumented Function
Safety Function:	Upon detection of inability to close / open valve within 500ms, poppet valve is closed (DETT) / opened (ETT) (Sensing and logic solver subsystems not part of this analysis)
Applied standard:	IEC 61508 Ed2 2010 Parts 1-3 & IEC 61511 Ed1
Systematic Capability:	Suitable up to SIL 2
Applicable report:	Environmental Resources Management Ltd Report: E058_SV001 rev. 6

Assessment Route:	1_H
Hardware Fault Tolerance:	0 or 1
Type:	A
Application restrictions:	None

Model No.	λDU (/hr)	λDD (/hr)	λS(/hr)	SFF	SIL AC (HFT = 0)	SIL AC (HFT = 1)	SIL SC
VTP Poppet Valve with actuator SXH / SXD DETT	3.6E-07	0.0E+00	8.7E-07	71%	SIL 2	SIL 3	SC 2
VTP Poppet Valve with actuator SXH / SXD ETT	1.1E-06	0.0E+00	9.1E-08	7%	SIL 1	SIL 2	SC 1

SIL AC (Architectural Constraints): Represents the maximum allowable SIL of each hardware element, assuming Hardware Fault Tolerance (HFT) = 0 or 1.

SIL SC (Systematic Capability): A measure of confidence (expressed on a scale of SC 1 to SC 4) of the confidence that the systematic safety integrity of a device meets the requirements of the specified SIL.

It should be noted that for a device to claim compliance with a specified SIL, the SIL AC and SC of the device needs to both be met. In addition to this, the required Average Probability of Failure on Demand (PFDavg) value for the complete Safety Instrumented Function (SIF) needs to adhere to the SIL PFDavg ranges.

© Copyright 2026 by The ERM International Group Limited and/or its affiliates ('ERM'). All Rights Reserved.

Document number:	E058_CT001 rev. 6
Dated:	22-Jan-26
Expiry date:	22-Jan-29

IMPORTANT: It should be noted that this assessment considers only the ROSS Pneumatrol Ltd, VTP Poppet Valve with SXH / SXD Actuator Assembly and does not include confirmation of the response time of the device(s).

The ROSS Pneumatrol Ltd, VTP Poppet Valve with SXH / SXD Actuator Assembly has been assessed and is considered capable for use in a low demand mode safety function up to (and including) SIL 3 with regards to random hardware failures, architectural constraints and systematic capability.

Note 1: The SIL of a complete SIF (sensor, logic solver and final element subsystems) must be verified to calculate the required Probability of Failure on Demand (PFD) / Probability of Failure per Hour (PFH), considering any redundancy, Proof Test Interval (PTI), Proof Test Coverage (PTC), Mission Time and Mean Time To Restoration (MTTR) for all elements included in the SIF. Each subsystem should be verified to ensure compliance with the minimum HFT requirements.

Chantal Sealey FS Eng (TÜV Rheinland) Assessor chantal.sealey@erm.com	Simon Burwood FS Expert (TÜV Rheinland) Assessment Authority simon.burwood@erm.com