Document number:	E046_CT003 rev. 13
Dated:	30-Sep-26
Expiry date:	30-Sep-29

IEC 61508 Functional Safety Capability Statement

Apollo Fire Detectors Ltd, Isolated Call Point

Manufacturer:	Apollo Fire Detectors Ltd 36 Brookside Rd, Havant PO9 1JR
Product:	Isolated Call Point
Model:	58100-908CD, 58100-971mar

Application:	Low Demand Mode Safety Instrumented Function
Safety Function:	Refer to Technis report
Applied standard:	IEC 61508 Ed2 2010 Parts 1-3 & IEC 61511 Ed1
Systematic Capability:	Suitable up to SIL 2
Applicable report:	Technis Report No. T616 Issue 2.0 Environmental Resources Management Ltd Report: E046_PU002 rev. 7

Assessment Route:	1_H
Hardware Fault Tolerance:	0
Type:	B
Application restrictions:	The certified devices can only achieve SIL 2 if used in conjunction with a fire alarm control panel that supports all elements of the Apollo protocol, including full fault diagnostic Safety Manual for each product covered by this document should provide a reference to the ERM assessment report

Model No.	λDU (/hr)	λDD (/hr)	λS (/hr)	SFF	SIL AC (HFT = 0)	SIL SC
58100-908CD Discovery SIL Isolated Call Point	1.1E-08	1.4E-07	1.1E-08	93%	SIL 2	SC 2
58100-971mar Marine Isolated Call point	1.1E-08	1.4E-07	1.1E-08	93%	SIL 2	SC 2

SIL AC (Architectural Constraints): Represents the maximum allowable SIL of each hardware element, assuming Hardware Fault Tolerance (HFT) = 0.

SIL SC (Systematic Capability): A measure of confidence (expressed on a scale of SC 1 to SC 4) of the confidence that the systematic safety integrity of a device meets the requirements of the specified SIL.

It should be noted that for a device to claim compliance with a specified SIL, the SIL AC and SC of the device needs to both be met. In addition to this, the required Average Probability of Failure on Demand (PFDavg) value for the complete Safety Instrumented Function (SIF) needs to adhere to the SIL PFDavg ranges.

© Copyright 2026 by The ERM International Group Limited and/or its affiliates ('ERM'). All Rights Reserved.

Document number:	E046_CT003 rev. 13
Dated:	30-Sep-26
Expiry date:	30-Sep-29

IMPORTANT: It should be noted that this assessment considers only the Apollo Fire Detectors Ltd, Isolated Call Point. It does not cover opening and closing time requirements and a random hardware failures assessment must be conducted for the entire safety function for each application as per the appropriate Safety Requirements Specification.

The Apollo Fire Detectors Ltd, Isolated Call Point have been assessed and are considered capable for use in a low demand mode safety function up to (and including) SIL 2 with regards to random hardware failures, architectural constraints and systematic capability.

Note 1: The SIL of a complete SIF (sensor, logic solver and final element subsystems) must be verified to calculate the required PFD / Probability of Failure per Hour (PFH), considering any redundancy, Proof Test Interval (PTI), Proof Test Coverage (PTC), Mission Time and Mean Time To Restoration (MTTR) for all elements included in the SIF. Each subsystem should be verified to ensure compliance with the minimum HFT requirements.

Chantal Sealey FS Eng (TÜV Rheinland) Assessor chantal.sealey@erm.com	Simon Burwood FS Expert (TÜV Rheinland) Assessment Authority simon.burwood@erm.com